


High Voltage




OBLUM

50 YEARS OF EXCELLENCE

Pioneering Cutting-Edge Solutions for Tomorrow



Powering Progress for Over
Half a Century: We've been
at the forefront of electrical
polymer surge arresters
manufacturing, continuously
innovating for 50+ years,
delivering solutions that
energize the world.





Global Presence

Oblum business operations are present in multiple geographies across the globe. We are committed to our vision of driving positive change in the environment and in the lives of people.

Asian Countries

- Philippines
- Iraq
- Bangladesh
- Srilanka
- Turkey
- Abu Dhabi
- Bhutan
- Malaysia
- Nepal
- Uganda
- Uae
- Afghanistan
- Vietnam
- Sharjah
- Nigeria
- Colombo
- Kabul
- Jordan
- Kenya
- Yemen
- Dubai
- Armenia
- Georgia
- Japan
- Kuwait



African Countries

- Kenya
- Rwanda
- Togo
- Mali
- Zambia
- Burkina Faso
- Mozambique
- Congo
- Tanzania
- Uganda
- South Africa
- Ivory Coast
- Ethiopia
- Botswana
- Liberia
- Transco Clsg
- Ghana
- Sierra Leone
- Gambia

South American Countries

- Peru
- Paraguay

North American Countries

- Nicaragua
- Canada

European Countries

- Finland
- Spain

High Voltage (132kv)

S No	Description	132kV 10kA SM	132kV 20kA SH
	Model	PBC	PBC
1	Highest system voltage kV rms	145	145
2	Nominal system voltage kVrms	132	132
3	Ur - Rated voltage kVrms	132	132
4	Uc - MCOV(kVrms)	112	112
5	In - NDC (8/20μs) kA	10	20
6	Arrester classification	Station Medium duty	Station High Duty
7	Qrs(IEC 99-4 Ed.3) in coulomb	1.6	2.4
8	Wth (IEC 99-4 Ed.3) in kJ/kV	7	10
9	Qth (IEC 99-4 Ed.3) in coulomb		
10	Max RDV kVp		
	a) 5kA	352	
	b) 10kA	374	330
	c) 20kA	418	352
11	Max. Switch. Imp. R.V.(kVp)		
	a) 500A		
	b) 1000A	299	
	c) 2000A		280
12	Max. Steep Current impulse RDV(kVp) at NDC	418	374
13	High current impulse withstand value (4/10 μs) kA	100	100
14	TOV (kVp)		
	i. 0.1	233	233
	ii. 1.0Sec	223	223
	iii. 10.0Sec	214	214
	iv. 100.0Sec	205	205
15	Short circuit current kA	40/50 (As applicable)	40/50 (As applicable)
16	Insulation Withstand		
	a) Lightning Impulse (kVp)	As per IEC 60099-4 2014	As per IEC 60099-4 2014
	b) Power frequency kVrms	As per IEC 60099-4 2014	As per IEC 60099-4 2014
	c) Switching Imp (Wet)(kVp)	NA	NA
17	Rated frequency (Hz)	48 to 62	48 to 62
18	Leakage current		
	a. IR at MCOV in μA	Less than 400	Less than 500
	b. IC at MCOV in mA	About 1.4	About 1.5
19	Reference voltage in Volt at Reference current in mA	> 132kV at 3mA	> 132kV at 4mA
20	Partial discharge P.D	10pC	10pC
21	Creepage distance-mm (min) Phase to Phase	25mm/kV /31mm/kV (as applicable)	25mm/kV /31mm/kV (as applicable)
22	Max. Cantilever strength of arrester Kgf	150	150

Exports/Technical :

Ms.Bhargavi

Ph: +91 89770 89857

E : bhargavi@oblum.co.in

overseas@oblum.co.in

Technical :

Mrs. Nagalakshmi

Ph :+91 9848352440

E : nagalakshmi.k@oblum.co.in

technical@oblum.co.in

Oblum Electrical Industries (P) Ltd.

#A-16&17, Assisted Private Industrial
Estate, Balanagar, Hyderabad - 500 037

Land Line: 040-2377 1880

GST : 36AAACO2289A1ZQ

www.oblum.co.in

